

# Missouri Department of Natural Resources



## PUBLIC NOTICE

### DRAFT MISSOURI STATE OPERATING PERMIT

DATE: November 19, 2004

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, Missouri 65102, ATTN: Peter Goode, NPDES Permits and Engineering. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curdt v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by December 19, 2004 or received in our office by 5:00 p.m. on December 22, 2004. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at DNR's website, <http://www.dnr.mo.gov/wpscd/wpcp/index.html>, or at the Department of Natural Resources, Water Protection Program, 205 Jefferson Street, P.O. Box 176, Jefferson City, Missouri 65102, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: November 19, 2004  
Permit Number: MO-0109819  
Kansas City Regional Office

<b>FACILITY NAME AND ADDRESS</b>	<b>NAME AND ADDRESS OF OWNER</b>
Basswood Country R.V. 15880 Inter Urban Road Platte City, MO 64079	Don Soper 15875 Inter Urban Road Platte City, MO 64079
<b>RECEIVING STREAM &amp; LEGAL DESCRIPTION</b>	<b>TYPE OF DISCHARGE</b>
Tributary to Platte River (Platte River) Sec. 27, T53N, R34W, Platte County	Domestic, modification

Plans and specifications for this facility have not been reviewed by the Department of Natural Resources in detail to determine its secondary treatment capability. A schedule of compliance is included in the special conditions for this operating permit. Dates in the schedule of compliance will be added when the construction is complete and the operating permit is issued. The design engineer, a registered Missouri professional engineer, has certified that the plans and specifications meet all requirements of 10 CSR 20-Chapter 8, Wastewater Treatment Facilities Design.

STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**  
MISSOURI CLEAN WATER COMMISSION



## MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No.	MO-0109819
Owner:	Don Soper
Address:	15875 Inter Urban Road, Platte City, MO 64079
Continuing Authority:	Same as above
Address:	Same as above
Facility Name:	Basswood Country R.V.
Facility Address:	15880 Inter Urban Road, Platte City, MO 64079
Legal Description:	NW ¼, NE ¼, Sec. 27, T53N, R34W, Platte County
Latitude/Longitude:	+3922551/-09442059
Receiving Stream:	Tributary to Platte River (U)
First Classified Stream and ID:	Platte River (P)(00312)
USGS Basin & Sub-watershed No.:	(10240012-130005)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

### FACILITY DESCRIPTION

Outfall #001 – Private Campground/Motel - SIC #4952

Bioclere<sup>TM</sup> unit utilizing an attached growth biological process with recirculation/sludge is hauled to the Kansas City Blue River Wastewater Treatment Plant.

Design population equivalent is 498.

Design flow is 14910 gallons per day.

Design sludge production is 4.2 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

---

Effective Date

---

Stephen M. Mahfood, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

---

Expiration Date  
MO 780-0041 (10-93)

---

Interim Director of Staff, Clean Water Commission

<b>A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS</b>					PAGE NUMBER 2 of 5	
					PERMIT NUMBER MO-0109819	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/month	24 hr. estimate
Biochemical Oxygen Demand <sub>5</sub>	mg/L		45	30	once/month	24-hour composite
Total Suspended Solids	mg/L		45	30	once/month	24-hour composite
pH – Units	SU	**		**	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE _____ THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I &amp; III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

MO 780-0010 (8/91)

#### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- \* Monitoring requirement only.
- \*\* This facility is required to meet a removal efficiency of 85% or more.
- \*\*\* pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

#### C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.
  - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
  - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

C. SPECIAL CONDITIONS (continued)

2. All outfalls must be clearly marked in the field.

3. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
  - (1) One hundred micrograms per liter (100 µg/L);
  - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
  - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

4. Report as no-discharge when a discharge does not occur during the report period.

5. General Criteria. The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:

- (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
- (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
- (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
- (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
- (e) There shall be no significant human health hazard from incidental contact with the water;
- (f) There shall be no acute toxicity to livestock or wildlife watering;
- (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
- (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

6. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities

- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
- (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

7. This permit may be reopened and modified or alternatively revoked and reissued, to incorporate new or modified effluent limitations or other conditions, if the result of a wasteload allocation study, toxicity test, or other information indicates changes are necessary to ensure compliance with Missouri's Water Quality Standards.

#### D. SCHEDULE OF COMPLIANCE

The proposed engineering design includes technology not addressed in Missouri Clean Water Commission Regulations 10 CSR 20-Chapter 8 design standards. To assess the effectiveness of the new technology at this facility, the following schedule of compliance is included:

1. The permittee acting under the supervision of a professional engineer registered in Missouri shall at a minimum, collect and test samples of wastewater treatment facility effluent as outlined in this permit, measure flow as outlined in this permit, and shall record all maintenance and operational problems experienced with the wastewater treatment facility during the first 34 months of operation. Other sample collection and testing including influent samples, and samples before and after each unit operation or group of unit operations, and other record keeping shall be done at the discretion of the professional engineer as needed to assess the new technology.
2. Within one (1) year of the date of issuance of this permit, the permittee shall submit a preliminary engineering report prepared by the professional engineer to the Kansas City Regional Office evaluating the new technology for the first ten (10) months of operation. At the minimum, this evaluation shall include:
  - (a) Calculation of the mean (average) test results for all wastewater treatment facility effluent sample results collected under this permit for all parameters that have a maximum average monthly permit limit except pH.
  - (b) Calculation of the standard deviation of all test results noted above based on the following:

$$StandardDeviation = \left[ \frac{(R_1 - M)^2 + (R_2 - M)^2 + (R_3 + M)^2 + \dots + (R_n + M)^2}{n - 1} \right]^{0.5}$$

where  $R_1, R_2, R_3$ , etc. are the individual sample results

n is the total number of samples

M - mean

- (c) Calculation of the Coefficient of Variation (cv) for all test results noted above based on the following:

$$cv = \left[ \frac{\text{Standard Deviation}}{\text{Mean}} \right]$$

- (d) Calculation of the Standard Deviation of Logarithms ( $\sigma$ ) for all test results noted above based on the following:

$$\sigma = \left[ \ln \left[ \frac{cv^2 + 1}{4} \right] \right]^{1/2}$$

where ln is the natural logarithm to base e

e is 2.718281828

- (e) Calculation of the Performance Standard (P) for 95<sup>th</sup> percentile probability for all test results noted above based on the following:

$$P = (\text{mean})e^{(z\sigma - 0.5\sigma^2)}$$

where z is 1.645 for 95 percentile probability

D. SCHEDULE OF COMPLIANCE (continued)

- (f) The new technology will be deemed successful if the performance standard for 95<sup>th</sup> percentile probability is less than or equal to the permit maximum monthly average limit for each parameter.
  - (g) The preliminary engineering report shall also assess any operational or maintenance problems experienced during the initial ten (10) months of operation and shall describe all measures taken to overcome these problems. The engineer shall provide an assessment of whether operation or maintenance problems are sufficiently serious to require replacement or modification of the proposed technology.
3. Within three (3) years of the date of issuance of this permit, the permittee shall submit a final engineering report prepared by the professional engineer to the Kansas City Regional Office evaluating the new technology for the first 34 months of operation including all of the items described in the initial ten (10) month evaluation. Again, the proposed technology will be deemed successful if the performance standard for 95<sup>th</sup> percentile probability is less than or equal to the permit maximum monthly average limit for each parameter.
  4. If the proposed technology fails to meet the 95<sup>th</sup> percentile probability performance standard for any parameter, or if the engineer assesses the operation and maintenance problems to be sufficiently serious to require replacement or modification of the proposed technology, the permittee shall submit engineering report, plans, specifications prepared by a professional engineer registered in Missouri along with construction permit application forms, filing fee to the Kansas City Regional Office within one hundred twenty (120) calendar days of the date of submittal of the preliminary or final engineering report evaluation that identified the failure. These documents shall outline modification or replacement of the failed proposed technology with any conventional technology.
  5. Within one hundred eighty (180) calendar days of receiving the construction permit, the permittee shall construct the replacement facilities and submit the Statement of Work Complete prepared by the professional engineer to the Kansas City Regional Office.